


1. RAMP FLARE TYPE "A" SHALL HAVE A BREAK IN THE FORMS AT THE TRADITIONAL 6' CURB RAMP
2. RAMP FLARE TYPE "B" MAY HAVE A CONTINUOUS FORM LINE FROM THE BACK OF THE CURB TO THE TURNING SPACE
3. THE SURFACE OF ALL CURB RAMPS SHALL BE BROOMED PERPENDICULAR TO THE SLOPE OF THE CURB RAMP
4. CARE SHALL BE TAKEN TO ASSURE A UNIFORM GRADE ON THE RAMP. FREE OF SAGS AND SHORT GRADE CHANGES.
5. DETECTABLE WARNING PANEL SHALL EXTEND THE FULL WIDTH OF THE CURB RAMP
6. TURNING SPACE SHALL HAVE MINIMUM DIMENSIONS OF 4 FT. x 4FT. AND SHALL BE A MINIMUM OF 1 FT. FROM ANY OBSTACLE SUCH AS A CURB OR RETAINING WALL FOR SWING OF WHEELCHAIR FOOT REST. THE SLOPE SHALL BE 2% MAXIMUM IN ANY DIRECTION.




CITY OF GRAND ISLAND
PUBLIC WORKS DEPARTMENT

DATE: 12/04/2017
DRAWN BY MWL
APPVD. BY KJK

CURB RAMP
Type 1

PLAN
160